



MAHARASHTRA STATE ELECTRICITY TRANSMISSION CO. LTD.

**Office of the Executive Engineer,
E.H.V. Projects Division, Kalyan.**

IInd floor, 'A' wing, 'Tejashri Bldg.', Jahangir Maidan, Karnik road,
M.S.E.T. Co. Ltd., Kalyan (W) 421 301.

Tel. – 0251 2328540

E-mail – ee7620@mahatransco.in

Ref. No. EE/EHV C/DN/KLN/T /No. 212

Date:- 07.02.2024


Sub: Extension to E-enquiry for submission of Quotations/ budgetary offer for Supply, Erection and foundation of 132KV Monopole with 0.2ASCR Pantherconductor , 220 KV Monopole with 0.4ASCR Zebra conductortowards estimation work of various departmental and ORC work under EHV Projects Dn, Kalyan

Dear Sir,

The Sealed Quotations/Budgetary offer are invited for the above mentioned work as per Scheduled – 'A', 'B' with following terms & condition:

1. The Quotation/Budgetary offer shall reach to this office from 07.02.2024 to 09.02.2024 up to 14:00 Hrs in sealed envelope only. This office shall not accept any responsibility for late receipt of quotations. The quotation will be opened on dt. 09.02.2024 (If possible).
2. The Quotation/Budgetary offer will be accepted from approved manufacturer of Monopole and approved MSETCL vendor only.
3. The Quotations/Budgetary offer will be on agencies letter head and valid for minimum 3 months.
4. The Ex-work price should be mentioned separately in the budgetary offer. All other applicable taxes to be quoted extra.
5. The undersigned reserve the right to reject any or all quotations without assigning the Reason thereof.

Encl: - Schedule A, B


Executive Engineer
E.H.V. Projects Dn. Kalyan

Schedule "A"

Sr.No	Particulars of item	Unit	Ex-work price		
			Supply	Erection	Foundation
1	132KV Pole-PD(30-60deg) +25Suitable for 0.2ASCR Panther Conductorand Wind Zone - 3 (44m/s)	Per Tower			
2	132KV Pole-PE(90deg)+25 Suitable for 0.2ACSR Panther conductor and Wind Zone - 3 (44 m/s)	Per Tower			

Note: - 1. 0.2ASCR Panther Conductor

2. Cross arm should carry DTN with 2 nos of jumpers

3. Taxes should be quoted separately in the quotation/ budgetary offer


4. As per approved drawing Height of cross Arm is 40.6Mtr for PD+25 Mtr.

5. As per approved drawing Height of cross Arm is 39.1Mtr for PE+25 Mtr.

6. Suitable for wind zone 3

7. Insulators: - Anti fog insulators

8. Ruling Span: - 320Mtr


Executive Engineer
E.H.V. Projects Dn. Kalyan

Schedule "B"

Sr. No	Particulars of item	Unit	Ex-work price		
			Supply	Erection	Foundation
1	220 KV Pole-PD(30-60deg) +27 Suitable for 0.4ACSR Zebra Conductor conductor and Wind Zone - 3 (44 m/s)	Per Tower			

Note: - 1. 0.2ASCR Panther Conductor

2. Cross arm should carry DTN with 2 nos of jumpers


3. Taxes should be quoted separately in the quotation/ budgetary offer

4. As per approved drawing Height of cross Arm is 43.90Mtr for PD+27 Mtr.

5. Suitable for wind zone 3

6. Insulators: - Anti fog insulators

7. Ruling Span: - 350Mtr


Executive Engineer
E.H.V. Projects Dn. Kalyan