

EHV PC O&M ZONE, KARAD,  
Administrative Building, 1st Floor Vijaynagar, Karad, 415114, Dist :  
Satara.  
Contact No.: Tel (O): 02164 255054, (O):02164 255191, Fax: 02164  
255186  
E-mail : [cekarad@mahatransco.in](mailto:cekarad@mahatransco.in)  
Website: [www.mahatransco.in](http://www.mahatransco.in)



Ref. No. CE/EHV PC O&M/ZONE/KRD/T/1186

Date :- **18.07.2024**

**E- ENQUIRY FOR BUDGETORY OFFER**  
**TO WHOM SO EVER IT MAY CONCERN**

Please find herewith a detailed schedule for Supply Installation & Commissioning of 82.5 KVA/66KW, 415 V Smart DG SET at EHV PC O&M Zone, Karad.

All interested & experienced Manufacturer/Authorized channel partners/bidders are requested to submit their best lowest budgetary offer for Supply Installation & Commissioning of 82.5 KVA/66KW, 415 V Silent & Smart DG SET as per enclosed schedule upto Dtd.25.07.2024 upto 18:00 Hrs on Email ID :- cekarad@mahatransco.in

1. **Site Visit:-** The bidders may visit to the site i.e. at EHV PC O&M Zone, Karad before submitting the budgetary offer.
2. **Due date:-** The budgetary offer complete in all respects should be E-mail to this office on or before 25.07.2024, 18:00 Hrs.
3. **Quoted rates :-** The quoted rates should include the cost of all skilled & unskilled labour, and also the requisite consumables, T&P and all incidental charges such as traveling, transportation, accommodation.
4. **Required Documents:-** The bidder should submit all the supporting & accompanying documents as per following details:-
  1. Registration under PAN
  2. Registered under GST.
  3. Valid registration/ intimation under Bombay Shop & Establishment Act, Udyog Aadhar/Factories Act/Companies Act.
  4. Valid electrical licenses (If any or undertaking).
  5. Certificate of authorize dealership/channel partner of the OEM if available.
5. **Terms & Condition:-**
  - a. Bidder should provide a Comprehensive Maintenance Contract for a period of minimum 3 years from commissioning of the project.
  - b. Performance Warranty for Smart DG Set will be for a period of 05 years from commissioning of the project.
  - c. Payment Terms : The 80% payment against supply, 10% against erection balance 10% against commissioning.
  - d. GST:- The GST @ 18% will be applicable.
  - e. Security deposit:-The Security deposit @ 5% of the ex works contract value will be kept till successful operation for a period of 01 (One) year from commissioning.

**Note:-** Please note that, this budgetary offer is only for estimation purpose & not considered for any bidding & no work order will be issued based on the budgetary offer.

The undersigned reserves the right to reject any or all budgetary offer without assigning any reasons.

Thanking you,

Yours faithfully,

**Chief Engineer,**  
**EHV PC O&M Zone, Karad**  
**(S/D)**

**Encl:** 1. Schedule 'A'.

**Copy To:** - A.G.M (F&A) EHV PC O&M Zone, Karad/M/F T

**EHV PC O&M Zone Karad**

**Sub:-** Supply Installation & Commissioning of 82.5 KVA/66KW, 415 V Smart DG SET at EHV PC O&M Zone, Karad.

**Schedule 'A'**

Sr. No.	Scope of Work	UoM	Qty	Ex Works Amt. in Rs.	Taxes @ %	Total Amt. in Rs.
1	DG Set:- CPCB IV preferably CRDI Technology(Common Rail Direct Injection), 82.5 KVA/66 KW SILENT Diesel Generating Set with acoustic enclosure, Radiator cooled, Diesel Engine developing minimum 101 BHP at 1500 RPM complete with standard accessories and DG Set controller with SRCP panel coupled to alternator rated at 82.5 KVA/66kW at 415 Volts, mounted on Channel Iron Base Frame complete with Fuel Tank of 150 Ltrs. capacity sub-base batteries AVM Pads,& Residential Silencer.	No.	1			
2	AMF/ ATS panel suitable for 82.5 KVA/ 66 KW	No.	2			
3	Suitable earthing alongwith supply of required material	No.	4			
4	Aluminum/ copper armoured cable of 70 Sqmm of any standard make confirming to IS	Mtr	30			
5	1.5 Sqmm, 4 core standard make sensing cable	Mtr	30			
6	Flexible copper cable for ATS & mains connections	Mtr	30			
7	Lugs, cable, clips & other consumables if any	LS	1			
8	Transportation, unloading of DG set at site	LS	1			
9	Labour charges for erection, commissioning, testing, cabling & earthing	LS	1			

**Chief Engineer,  
EHV PC O&M Zone, Karad  
(S/D)**