

**MAHARASHTRA STATE ELECTRICITY TRANSMISSION COMPANY LIMITED**

**MAHARASHTRA STATE ELECTRICITY TRANSMISSION CO.LTD.**

**(CIN No – U40109MH20055GC153646)**

**Office of the Executive Engineer, 400kV R. S. (O&M) Division  
PADGHE-421 101 Tal: Bhiwandi Dist-Thane(Maharashtra, India)**

**Phone : 9920117819(P), 9920934025(P), 9769006230(CR),**

**Mail: [ee7330@mahatransco.in](mailto:ee7330@mahatransco.in)/[ee400kvpadghe@gmail.com](mailto:ee400kvpadghe@gmail.com)**

**Web: [www.mahatransco.in](http://www.mahatransco.in)**



**No.EE/400KV/RS(O&M)DIV/PDG/Tech/ C C C 3 9 8**

**Date: 02 JUN 2025**

**E- Enquiry (for Budgetary offer)**

**Subject: -2<sup>nd</sup> call for Enquiry for submission of Budgetary offer for supply & Installation of Transducer at 400 at 400kV RS O&M Dn Padgha.**

**Dear Sir,**

The Sealed Quotations/Budgetary offer are invited for the above mentioned work as per Scheduled - 'A' with following terms & condition:

1. The Quotation/Budgetary offer shall reach to this office upto 11.06.2025 up to 15:00 Hrs in sealed envelope only. This office shall not accept any responsibility for late receipt of quotations. The quotation will opened on dt. 11.06.2025 (If possible).
2. This enquiry is solely for collection of offer for estimate purpose & not for work allocation.
3. The Quotations/Budgetary offer will be on agencies letter head and valid for minimum 3 months.
4. The Ex-work price should be mentioned separately in the budgetary offer. All other applicable taxes & other charges if any to be quoted extra.
5. The undersigned reserve the right to reject any or all quotations without assigning the Reason thereof.

**Executive Engineer  
400 kV RS (O&M) Division, Padghe**

**Subject: 2<sup>nd</sup> call for Enquiry for submission of Budgetary offer for supply & Installation of Transducer at 400 at 400kV RS O&M Dn Padgha..**

**Schedule -A**

Sr no	Description	Unit	Qty.	Ex-work price
	<b>Supply Part</b>			
1	Supply of Temperature transducer with power supply unit having 4-20 mA input from local OTI/WTI, Range 0-150 deg C and having 2 nos of 4-20 mA DC output. Auxiliary supply 90-260 V AC/DC. Burden on signal outputs more than 600 Ohm. Mounting suitable for Din Rail or screw fixing.	EA		
2	Supply of current converter unit suitable to connect OTI/WTI the output to be connected to temperature transducer or remote indicator shall be compatible with existing OTI/WTI.	EA		
3	Installation of Transducer, Dual Output, 4-20mA, suitable with provision of fitting in outdoor Marshalling Kiosk (MK)	EA		

- Note:- 1. The budgetary offer should be valid for at least 3 Months.  
2. Applicable taxes & other charges if any should be quoted clearly & separately.

  
**Executive Engineer**  
**400 kV RS (O&M) Division, Padghe**