

## MAHARASHTRA STATE ELECTRICITY TRANSMISSION CO. LTD.

Office of The Executive Engineer 400 KV R.S O&M Division, Kalwa PO Box No. 5 Airoli Navi Mumbai 400 708 Phone No. 022-27601893, 94 E-Mail:-ee7140@mahatransco.in CIN No.U40109MH2005SGC153646.

Date:- 13 JUN 2025 Ref: EE/400KV/RS/O&M/Dn/KLW/Tech/25-26/ 0 0 4

> **E-ENQUORY** (Through MSETCL webpage)

To. WHOM SO EVER IT MAY CONCERN

Sub:- Enquiry for Supply of 245kV Circuit breaker for 63kA STC spring -spring mechanism, single pole & gang operated at 400KV RS Kalwa.

.....submission of budgetary offers thereof.

This office has to prepare estimate for Supply of 245kV Circuit breaker for 63kA STC spring-spring mechanism, single pole & gang operated at 400KV RS Kalwa. It is requested to offer your favorable budgetary offer for the subject work as detailed in the enclosed price

- 1. DUE DATE:- The quotations, complete in all respects, duly sealed & super scribed should be submitted to this office on or before due date i.e. 23.06.2025.
- 2. QUOTED RATES:- The quoted rate should include the cost of all skilled & unskilled labour, and also the requisite consumables, T&P and all incidental charges such as traveling / transportation, accommodation, Freight insurance, labour cess etc.
- 3. DOCUMENT SUBMISSION:- The bidder should submit all the supporting and accompanying documents (i. e. PAN, GST certificate, Shop & Establishment certificate etc.) required for execution of work in sealed Envelope to this office.
- 4. Please note that the said budgetary offer is only for estimate purpose & not considered for any bidding & No work order will be issued based on this Enquiry.

Thanking you.

Yours faithfully,

Executive Engineer 400KV R.S. (O&M) Dn. Kalwa

Encl: Schedule 'A'.

## MAHARASHTRA STATE ELECTRICITY TRANSMISSION CO. LTD. 400KV RS O&M DN KALWA

## Schedule A

**Sub:-** Supply of 245kV Circuit breaker for 63KA STC spring –spring mechanism, single pole & gang operated at 400KV RS Kalwa.

Sr. No.	Description	Unit	Ex Rate	GST	F&I @2 %	Labour Cess@ 1%_	Unit Rate
1	Supply of 245kV Circuit breaker for 63kA,STC spring -spring, mechanism at 400KV RS Kalwa with following specification.  1.NORMAL CURRENT – 3150A.  2. POWER FREQUENCY WITHSTAND VOLTAGE –460 KVrms.  3. LIGHTNING IMPULSE WITHSTAND VOLTAGE –1050 KV peak  4. FIRST-POLE-TO-CLEAR FACTOR-1.3  5. SHORT - TIME WITHSTAND CURRENT-63KA  6. DURATION OF SHORT CIRCUIT-3s  7. SHORT - CIRCUIT BREAKING CURRENT SYMMETRICAL-63kA, ASYMMETRICAL-61.2kA  8. SHORT - CIRCUIT MAKING CURRENT-125kAp  9. OUT-OF-PHASE BREAKING CURRENT-125kA  10. LINE CHARGING BREAKING CURRENT-125A  11. OPERATING SEQUENCE - O - 0.3s - CO - 3min – CO						
A	Single Pole Operated	EA					× 1
В	Mechanical Gang Operated (MGO)	EA					

Executive Engineer 400KV R.S. (O&M) Dn, Kalwa