



MAHARASHTRA STATE ELECTRICITY TRANSMISSION CO.LTD.

From:-Office of The Executive Engineer,
EHV(O&M) Division, Kalwa
Brahmaputra Building, 2nd floor,
Power House Complex, Post Box No 4, Airoli,
Thane-Belapur Rd., Navi Mumbai- 400708.
Tel. : 022- 2760 1919, FAX : 022- 2760 1919
CIN No: U40109MH2005SGC153646
Web Site:www.mahatransco.in
E-mail ID – eekalwa@gmail.com

Ref No.: EE / EHV/ O&M/ KLW/T- / 002007

Date: - 23 JUN 2025

ENQUIRY
(Through MSETCL webpage)

To,
WHOM SO EVER IT MAY CONCERN

Sub.: Enquiry for procurement of resin cast 24 kV CT of various ratios for 22kV indoor switchgears at Various Substations under EHV O&M Division Kalwa.
..... **Submission of budgetary offers thereof**

This office has to be prepared an estimate for procurement of resin cast 24 kV CT of various ratios for 22kV indoor switchgears at 220/22kV Substations under EHV O&M Division Kalwa.

It is requested to offer your favorable budgetary rate for the subject work as detailed in the enclosed Price estimate.

1. DUE DATE: - The quotations, complete in all respects, duly sealed & super scribed should be submitted to this office on or before due date i.e., Dt 30.06.2025. The published period of enquiry is from 23.06.25 to 30.06.25.

2. QUOTED RATES: The quoted rates should include the of work of for procurement of resin cast 24 kV CT of various ratios for 22kV indoor switchgears at Various Substations under EHV O&M Division Kalwa. including T&P and all incidental charges such as traveling/ transportation, accommodation etc.

3. SCOPE of Work: Work should be included work for procurement of resin cast 24 kV CT of various ratios for 22kV indoor switchgears at Various Substations under EHV O&M Division Kalwa.

4. Technical Specification of work:

Sr. No.	Description	Unit	Ex work Rate
1	24kV Resin Cast CT 1600-800/1A (3C) 20VA Technical specification :- Protection Core :-PS Class 20VA Metering Core :- 0.2S Class 20VA Insulation class :-B,BIL-24/50/125 kVp	EA	


	Frequency -50HZ, OCF-120% STC-31.5kA/3Sec, Type-Window Standard -IS 2705-1992		
2	24kV Resin Cast CT 800-400/1A (3C) 20VA Technical specification:- Protection Core :-PS Class 20VA Metering Core:- 0.2S Class 20VA Insulation Class :-B,BIL-24/50/125kVp Frequency -50HZ, OCF-120% STC-31.5kA/3 Sec,Type-Window Standard -IS 2705-1992	EA	
3	24kV Resin Cast CT 400-200/1A (3C) 20VA Technical specification :- Protection Core :-PS Class 20VA Metering Core :- 0.2S Class 20VA Insulation class :-B,BIL -24/70/170kVp Frequency -50HZ,OCF-120% STC-31.5kA/3 Sec,Type-Wound Standard -IS 2705-1992	EA	

Note :- Please mention & consider F&I Extra Labour Cess- Extra, GST-Extra.

- 5. DOCUMENT SUBMISSION:** The bidder should submit all the supporting and accompanying documents required for execution of work in sealed Envelope to this office.
- 6. Please note that the said budgetary offer is only for estimate purpose & not considered for any bidding & No work order will be issued based on this Enquiry.**

Thanking you,

Yours faithfully,


**Executive Engineer,
EHV (O&M) Dn., Kalwa.**

Copy to: 1) The Manager (F&A), EHV (O&M) Dn., Kalwa.
2) Notice board.