
 <p>MAHATRANSCO Maharashtra State Electricity Transmission Co. Ltd.</p>	<p align="center">MAHARASHTRA STATE ELECTRICITY TRANSMISSION CO. LTD. Government of Maharashtra (Undertaking) (CIN: U40109MH2005SGC153646) OFFICE OF THE EXECUTIVE ENGINEER EHV O&M DIVISION, MANCHAR DSK's Pride , Survey No-170/7B, Pune-Nashik Highway, In front of Rural Health Centre, Manchar , Tq- Ambegaon Dist: Pune-410503 E-mail: ee61A0@mahatransco.in, eemanchar404@gmail.com Ph- 02133-223040/41</p>	
---	--	---

EE/EHV/O&M/Division/Manchar/Tech/No. 538

Date: 02.07.2025

To,
WHOM SO EVER IT MAY CONCERN

Subject:-Calling a budgetary offers in r/o work of supply of electrical maintenance kit at various EHV Sub-Stations under Manchar Division.

Dear Sir,

The budgetary offers through e-mail are hereby invited for the above work as per **Schedule 'A'** mentioned below:-

Sr. No.	Particulars	UOM	Ex Rate	GST	Unit Rate
1	<u>Supply of Electrical Maintenance Kit with</u> 1. Electrical contact cleaner (465 ml) 2. Greaseless Lubricant (379 ml) 3. Penetrant for Nut Bolt (382 ml) 4. Premier Rust Inhibitor (380 ml) 5. Corrosion Inhibitor (336 ml) 6. Steel Sticks <u>Specifications as per Annexure-I</u>	EA			

Note:- Rate shall be valid for 60 days from the date of submission of offer.

You are requested to quote your best reasonable rate for the above work. The Terms & Conditions are as follows.

Terms & Conditions:-

- 1) The rate should be quoted on firm quotation basis.
- 2) The rates should be exclusive of all taxes. Taxes should be quoted extra.
- 3) You are requested to submit your best reasonable budgetary offer as per Schedule 'A' for above works on **E-mail ID: ee61A0@mahatransco.in up to 11:00 Hrs on dtd. 11.07.2025.**
- 4) Following documents should be submitted along with your offer:-
 - a) Shop Act / Udyog Aadhar Registration Certificate.
 - b) Work Experience Certificate for similar nature of works in MSETCL/MSEDCL/ in any Power Utility or in Private Company in India.
- 5) **Please note that said budgetary offer is only for estimate purpose & will not be considered for any bidding & no work order will be issued based on this offer.**

Thanking you,

Yours Faithfully

Sd/-
(S R Wagh)
Executive Engineer
EHV O&M Division Manchar

Annexure-I

Sr. No.	Material Description	Technical Specifications	Specifications and Approvals
1	CFC Free Electro Contact Cleaner	Boiling point / Range 140.9 ⁰ F (60.5 ⁰ C) Vapor pressure 352.53mm Hg @ 38 ⁰ C	AMS1525 B ASTM F-519 type 1 C
2	Cold Galvanize Corrosion Inhibitor	Vapor pressure >1kPa @25 ⁰ C	ASTM A-780
3	Penetrant	Boiling point / Range 383 ⁰ F (195 ⁰ C) Vapor pressure < 0.1 mmHg @ 20 ⁰ C	A-A-50493 Class B Type I &II ASTM F-945
4	Strong Steel Sticks Renewal Composite	Compression strength 8.000 psi (55MPa) Dielectric strength 300 Volts / Mil Electrical resistance 30000 Megaohms Full cure time 24 Hrs @ 75 ⁰ F (24 ⁰ C) Hardening time 20 Minutes @ 75 ⁰ F (24 ⁰ C)	ASTM D 695 ASTM D 1706
5	Greaseless Lubricant	Boiling point / Range 415.4 ⁰ F (213 ⁰ C) Vapor pressure < 0.05 mmHg @ 20 ⁰ C Percent Volatile 95 – 96%	Es-2092 BAMS 569-001 MIL-C-23411A
6	Premier Rust Inhibitor	Boiling point / Range 320 ⁰ -392 ⁰ F Vapor pressure < 2.6 mmHg @ 20 ⁰ C	AIMS 09-08-001 ASTM F-945 BMS 3-23G Type II Class I

Sd/-
(S R Wagh)
Executive Engineer
EHV O&M Division Manchar