

MAHARASHTRA STATE ELECTRICITY TRANSMISSION COMPANY LTD
(CIN NO- U40109MH2005SGC153646)

From,
Executive Engineer
PAC Division, Kolhapur-416005
Off-0231-2662668 E-mail: - ee3530@mahatransco.in

MSETCL/EE/PAC/Dn./Kop/T/ 230

Date : - 28.07.2025

E- Enquiry (Budgetary offer)

Sub :- Enquiry for submission of budgetary offer for Supply, installation, testing & commissioning of Remote terminal units (RTU) at 04 No's of substations under EHV PAC Division Kolhapur..

Dear Sir,

Budgetary offers are invited by the undersigned for Supply, installation, testing & commissioning of Remote terminal units (RTU) at 04 No's of substations under EHV PAC Division Kolhapur **on or before: 04.08.2025 up to 17:00 Hrs.** The other terms and conditions are as mentioned below.

- 1) Quotation should be duly filled in and submitted to this office **via post or e-mail** – **ee3530@mahatransco.in**
- 2) **This enquiry is solely for collection of offer for estimate purpose & not for work allocation.**
- 3) The offer should be submitted as per details mentioned below.
- 4) Quote rate in prescribed format.

Sr. No.	Particulars	Qty. in Nos.	Rate per unit in Rs. (Excl Gst)	Amount in Rs. (Incl Gst)
A	Supply of RTU having following specification 1) Compliance to IEC 61850 & IEC104, 2) Serial Port:- RS232 and RS485 ports, 2 ports each (RS 232 for IEC 101 Data out & RS 485 for MFM Data IN) 3) No. of Ethernet port:- RJ45 - 4 Nos. 4) Driver support for OS Linux & windows 5) CPU-quadcore 1.2Ghz or higher 6) Memory 4GB RAM or higher 7) Storage- 4GB flash as standard option to expand up to 256GB SSD. 8) Universal Power supply 24 – 230 V AC / DC only AC not acceptable. 9) No. of relays are to be integrated in RTU up to 80 No's 10) AI- 4-20mA, 2-3kV isolation 11) DI/DO- Capable 80-300V DC, 2-3kV isolation.			
1	RTU with DI & AI (No of DI 60/No of AI 16) having above specifications.	01		
2	RTU without DI/DO/AI having above specifications.	03		
B	Installation, configuration testing & commissioning of Remote terminal units (RTU) at 1) 400 KV Talandage 2) 220 KV Mudshingi 3) 220 KV Tilawani 4) 132 KV Bambwade	04		
	Total including GST			

-sd-

Executive Engineer
PAC Division Kolhapur.