

MAHARASHTRA STATE ELECTRICITY TRANSMISSION CO.LTD.

| |
|---|
| Office of The Executive Engineer, ±500 KV HVDC T&T Division. PADGHA - 421 101 Tal: Bhiwandi Dist-Thane Phone No. : 8554989485 E - mail: ee7350@mahatransco.in Website : www.mahatransco.in |
|---|

Ref.No.: MSETCL/EE/500 kV HVDC T&T /Dn./PDG/No.0335

Date:25.08.2025

NOTIFICATION FOR BUDGETARY OFFERS

Sub: - Supply of Digital MW Indicator, Digital kV Indicator, Digital kA Indicator and RS485 Communication Cable at HVDC T&T Unit Padgha under HVDC RS(O&M) Circle, Padgha.

Sir/Madam,

Budgetary Offers are invited from the MSETCL registered vendors as per schedule A given below & as per under given terms and conditions:-

SCHEDULE -A

| Sr. No. | Description | Unit | Qty | Rate (Ex-works) |
|---------|--|-------|-----|------------------|
| 1. | Supply of Digital MW Indicator, (4 digits 0.5" LED display, input: 4-12-20 mA corresponds to (-1250 to 0 to +1250) MW, Resolution :1, Accuracy: Class 0.5, Communication: Two outputs: 1. Isolated RS485 and 2. 4 to 20 mA, Aux supply:90-270 VAC/DC, Dimension:96X96 panel mountable) | EA | 2 | |
| 2. | Supply of Digital KV indicator (4 digits 0.5" LED display, input: 4-12-20 mA corresponds to (-600 to 0 to +600) KV, Resolution : 1, Accuracy Class 0.5, Communication: Two outputs: 1. Isolated RS485 and 2. 4 to 20 mA. Aux supply:90-270 VAC/DC, Dimension:96X96 panel mountable) | EA | 2 | |
| 3. | Supply of Digital KA indicator (4 digits 0.5" LED display, input: 4 to 20 mA corresponds to (0 to 2.5) KA, Resolution : 0.01, Accuracy Class 0.5, Communication: Two outputs: 1. Isolated RS485 and 2. 4 to 20 mA. Aux supply:90-270 VAC/DC, Dimension:96X96 panel mountable) | EA | 2 | |
| 4. | Supply of RS485 Communication Cable 1 pair shielded (Make: 24 AWG stranded (7X32) tinned copper conductors, LDPE insulation, 2 core Overall Beldfoil® Shield, unarmoured, Overall Shield & Drain, 300V, OD: 5.88 mm, EIA RS-485 Data Transmission Application) | meter | 50 | |


Note: - Please mentioned in budgetary offer that the Ex-works rates are inclusive of other taxes (i.e. Fright & Insurance etc.) or exclusive of other taxes.

Terms & conditions:-

1. GST at 18% will be applied on these items.
2. This enquiry is solely for collection of offer for estimate purpose & not for work allocation.
3. The conditional offer should not be submitted.

4. The offer should be submitted as per details mentioned above.
5. Quote rate in prescribed format & Attached Specifications in Schedule-A.
6. Validity of offer period should be mentioned on the offer letter.
7. The offers should reach within 10 days from date of the issue of notification on website.

Such sealed offers need to be sent on letter head with due company seal and sign of authorized person in hard copy to this office address as mentioned above.


Executive Engineer
±500 KV HVDC T&T Div. Padgha.

