



MAHARASHTRA STATE ELECTRICITY TRANSMISSION CO. LTD.

Name of Office : 400KV RS O&M Dn. Karad.
Office Address : Administrative Building, Ground Floor, Vijaynagar,
Post – Supane, Tal – Karad Dist – Satara, Pin No. 415114
Contact No. : 02164-255182 Fax. No. 02164-255182
Email ID : ee3130@mahatransco.in
Website : www.mahatransco.in.
CIN No. : U40109MH2005SGC153646

EE/400KV/RS/O&M/DN/KRD/T/No. **No 00515** Date: 02.09.2025.

1ST EXTENSION OF E-ENQUIRY FOR BUDGETORY OFFER
(Through MSETCL web page)

TO WHOM SO EVER IT MAY CONCERN

BUDGETARY OFFER

Please find attached herewith a detail schedule for **Requirement of 220kV FRP Hot Stick at 400kV RS Karad.** All interested & experienced bidders are requested to submit their best lowest **budgetary offer** on the **Mail ID : ee3130@mahatransco.in** or submit physically to this office for the same upto Dtd.04.09.2025. Taxes should be quoted distinctly if any.

Please note that this budgetary offer is for estimation purpose only.


(C.L.Bharamgunde)
Executive Engineer
400KV RS(O&M)Dn.Karad

MAHARASHTRA STATE ELECTRICITY TRANSMISSION COMPANY LTD
400KV RS (O&M) Division, Karad
(CIN No.- U40109MH2005SGC153646)

SCHEDULE 'A'

Sub :- Requirement of 220kV FRP Hot Stick at 400kV RS Karad.

Sr. No.	Description of Material	Unit	Qty.	Rate per unit Rs.	Applicable rate of GST	Total Rs.
	220kV FRP Hot Stick at 400 kV RS Karad					
1.	Type: sectional rigid FRP hot stick for 220kV systems. At least 6 to 7 mtr. long					
2.	Attachments: Hook, push-pull head, clamp.					
3.	Accessories: Carry case and storage rack.					

NOTE :-

- **Standards:** IEC 60855-1 / ASTM F711 compliant.
- **Construction:** High-strength, moisture- and UV-resistant FRP with insulated grip.
- **Quantity:** 3 complete hot stick sets with attachments for operation and maintenance.

➤ This budgetary offer is only for estimation purpose only.


(C.L. Bharamgunde)
Executive Engineer
400KV RS(O&M)Dn.Karad