



MAHARASHTRA STATE ELECTRICITY TRANSMISSION CO. LTD.

Name of Office : 400KV RS O&M Dn. Karad.
Office Address : Administrative Building, Ground Floor, Vijaynagar,
Post – Supane, Tal – Karad Dist – Satara, Pin No. 415114
Contact No. : 02164-255182 Fax. No. 02164-255182
Email ID : ee3130@mahatransco.in
Website : www.mahatransco.in.
CIN No. : U40109MH2005SGC153646

EE/400KV/RS/O&M/DN/KRD/T/No.

No 00516

Date: 02.09.2025

1ST EXTENSION OF E-ENQUIRY FOR BUDGETORY OFFER

(Through MSETCL web page)

TO WHOM SO EVER IT MAY CONCERN

BUDGETARY OFFER

Please find attached herewith a detail schedule for Requirement of **220V DC Battery Bank for DC power pack at 400kV RS Karad Substation**. All interested & experienced bidders are requested to submit their best lowest **budgetary offer** on the Mail ID : **ee3130@mahatransco.in** or submit physically to this office for the same upto Dtd.04.09.2025. Taxes should be quoted distinctly if any.

Please note that this budgetary offer is for estimation purpose only.

(C.L. Bharamgunde)
Executive Engineer
400KV RS(O&M)Dn.Karad

MAHARASHTRA STATE ELECTRICITY TRANSMISSION COMPANY LTD
400KV RS (O&M) Division, Karad
(CIN No.- U40109MH2005SGC153646)

SCHEDULE 'A'

Sub :- Requirement of 220V DC **Battery Bank** for DC power pack at 400kV RS Karad Substation.

Sr. No.	Description of Material	Unit	Qty.	Rate per unit Rs.	Applicable rate of GST	Total Rs.
	220V DC Battery Bank for DC power pack at 400kV RS Karad Substation.					
1.	Type: VRLA (Valve Regulated Lead Acid) / SMF (Sealed Maintenance Free)					
2.	Accessories: Interlinking cables and connectors to be supplied along with battery set					

NOTE :-

- Rating: 12 V, 12 Ah each
- Quantity: 36 Nos. (connected in series for 220 V DC output)
- Design Life: Minimum 5 years (at 27°C ambient)
- Compliance: IS 15549 / IEC 60896
- Warranty: Minimum 24 months from supply

➤ **This budgetary offer is only for estimation purpose only.**


(C.L. Bharamgunde)
Executive Engineer
400KV RS(O&M)Dn.Karad