



MAHARASHTRA STATE ELECTRICITY TRANSMISSION CO. LTD.

Name of Office : Executive Engineer, PAC Division, Sangli.
Office Address : PAC Division ,Near 110KV Vishrambag Substation,
Vishrambag, Sangli. Pin-416415
Email ID : ee3520@mahatransco.in
Website : www.mahatransco.in.
CIN No. : U40109MH2005SGC153646

Ref No. EE/PAC/SGL/Tech/No.155

Date:- 13.11.2025

Budgetary offer
(Through MSETCL webpage)
TO WHOM SO EVER IT MAY CONCERN

Dear Sir,

The budgetary offers invited for preparation of estimate for Supply, Installation, configuration testing & commissioning of 1 No. Ethernet Switch for SAS/SCADA system at 220kV Jath Substation under EE, PAC Division Office, Sangli as per Schedule A. You are requested to quote your lowest rates as per schedule attached herewith

SCHEDULE 'A

Sr. No	Particular	Qty	Rate/ Unit (Incl. all Taxes)
1	Ethernet Switches The new switch must meet the following specifications: 1. Industrial managed L2/L3 Ethernet switch complying with IEC 61850-3 & IEEE 1613. 2. Minimum 8×10/100/1000Base-T RJ45 ports and 8 no ST connector fiber ports (multimode/singlemode). 3. Support for VLAN, QoS, IGMP snooping, PRP/HSR redundancy, IEEE 1588v2 PTP, and RSTP/MRP. 4. Dual redundant power inputs (110/220VDC), fanless substation-grade design. 5. Operating temperature: -40°C to +85°C, humidity up to 95% non-condensing. 6. SNMP v3/SSH/web management with alarm relay outputs.	1	
2	Installation, configuration testing & commissioning of Ethernet Switches	1	

The rates should be inclusive of all taxes and charges.

Note:-

- 1) Please note that said budgetary offer is only for estimate purpose & not considered for any bidding & no work order will be issued based on this Enquiry.
- 2) All interested bidders are requested to submit their best reasonable budgetary offer for above works via Post/by hand to PAC Division of Sangli.via Email ID: ee3520@mahatransco.in upto 18:00 Hrs on Dtd. 19.11.2025

Thanking you,

Yours Faithfully
-sd-
Executive Engineer
PAC Division, Sangli.