

**MAHARASHTRA STATE ELECTRICITY TRANSMISSION CO. LTD.**

<b>Name of Office</b>	: Executive Engineer, EHV O&M Division, Latur.
<b>Office Address</b>	: Padlile complex, second floor, near ST bus work shop, Ambejogai Road, Latur-413512
<b>Contact No.</b>	: 02382-245208(O), 8554995015
<b>Email ID</b>	: eelaturdn@gmail.com, ee2220@mahatransco.in.

Ref. No. : EE/EHV/O&M/LTR/TS/ **1487**

Date: - **26 APR 2018**

**E-Enquiry**

**Sub :-E-Enquiry for the Work of Vermin proofing and anti corrosive treatment to the Marshalling Boxes of CT, PT, ACDB, Isolator Boxes and indoor Panels at 132 kV Ahmedpur S/s ,132 kV Chakur S/s under EHV (O&M) Dn, Latur.**

Dear Sirs,

Sealed and super scribed quotations are invited for the work as specification given below. The quotation giving full particulars should reach this office on or before **04.05.2018**.., up to 15.00 Hrs positively. The Taxation liability should show separately. Rights of cancellation/modification of E-Enquiry at any stage, is reserved at this office.

**Schedule 'A'**

Sr. no.	Particular	Unit	Qty	Rate/ Unit	Rate/Unit (Including GST	Amount (Rs.)
A	Work of Vermin proofing and anti corrosive treatment to the Marshalling Boxes of CT, PT, ACDB, Isolator Boxes and indoor Panels					
1	Size : 760 x 300 x1260mm CTMB	No.	8			
2	Size : 750 x 400 x1100mm Breaker Box	No.	7			
3	Size:820 x 250 x700mm CTMB	No.	10			
4	Size : 600 x 300 x1000mm CB BOX	No.	2			
5	Size: 760x 300x1260mm PTMB	No.	5			
6	Size: 1100 x 400 x 1050mm CB Box	No.	8			
7	Size:760 x760 x 2230mm 132 kV and 33 kV indoor panels	No.	13			
<b>Total (Rs.)</b>						

**Estimated amount for the above work: Rs. 2,94448.94/- (Inclusive of all Taxes).**

**Scope of work:-**

1. Cleaning by Surface / Brush /sand paper / Chemicals remove loose scale, old paint rusting etc.
2. Repairs of Panel, holes, etc. work will be done as per requirement.
3. Providing and Fixing of MS Sheet
4. Providing and Fixing of Rubber Gasket.
5. Providing and Fixing of MB's Hinge's.
6. Providing and Fixing of MB's Lock's.
7. Application of Epoxy Putty Epoxy coat 3201 & Hardener EP 26 Mixing Two Coat.
8. Application of Epoxy Resin & Hardener with Silica powder Two Coat.
9. Application of Enfield LF Resin & Hardener Mixing primer Two Coat.
10. Application of Epoxy Resin & Hardener Mixing primer Two Coat.
11. Application of Epoxy Resin PU Smoke grey Two Coat.
12. Application of Epoxy Green / With Coat of MB's in side & Out Side Two Coat.

**Note:- Zerox signed copies of below mentioned documents should be attached along with quotation.**

- a) PAN Card.
- b) GST registration Certificate
- c) Bombay Shop Act License
- d) Electrical Contractor License.
- e) Experience certificate of same work.

Thanking You

  
**Executive Engineer,  
EHV O&M Division Latur**

**Copy s.w.r.to:-** The Superintending Engineer, EHV (O & M) Circle, Parli(V).