

**MAHARASHTRA STATE ELECTRICITY TRANSMISSION CO. LTD.****CIN No.U40109MH2005SGC153646**

Name of Office :- EHV PROJECT DIVISION, NANDED.  
Office Address :- 132 KV S/S JANGAMWADI, CAMPUS, MSETCL NANDED- 431605  
Contact No. :- 02462 - 263105 (O), 02462 - 264107 (Fax), 02462 - 260107 (P)  
Email :- ee2630@mahatransco.in ;

Ref. No. EE/EHV/PROJ/DIV/NND/T/963

Date :- 29 JUL 2019

E-Enquiry No.

**Subject:- E-Enquiry** for the work of Oil filtration of 132/33 kV 25 MVA AREVA make T/F at 132 kV Substation Sengaon under EHV Project Division Nanded.

Dear Sir,

Sealed & super scribed quotation are invited from date **31.07.2019 at 12:00 hrs**, so as to reach this office up to date **07.08.2019 up to 12:00 hrs** for Work of Oil filtration of 132/33 kV 25 MVA AREVA make T/F at 132 kV Substation Sengaon under EHV Project Division Nanded on following terms & conditions:-

**TERMS AND CONDITIONS:-**

1. The Rate shall be quoted on firm quotation basis.
2. The rates should be quoted excluding of taxes. The taxes if any should be quoted extra.
3. The quotation should be sent under sealed cover duly super scribed as QUOTATION FOR Repairing the work of Oil filtration of 132/33 kV 25 MVA AREVA make T/F at 132 kV Substation Sengaon (Enquiry No. \_\_\_ be quoted).
4. Your quotation should reach this office **on or before 07.08.2019 up to 12:00 hrs** and the same will be Opened on the same day, if possible.
5. The rates shall be quoted in **Percentage Only** on **Total amount of the schedule**. The rates and amount shall be written both in Words and figures. The rates shall be written legibly and shall be free from eraser. The rates quoted shall include all the machineries, T&P and personnel required for executing the works.
6. Income tax & W.C. tax will be recovered as per prevailing rules.
7. The rates offer submitted by you should be valid for at least 90 days from the last date of receipt of quotation.
8. Payment will be effected by this office by cheque after satisfactory completion of work.
9. Required Documents:-
  - 1) GST Registration with returns.
  - 2) Valid Electrical License.
  - 3) PAN Card & PT Registration etc.
  - 4) Experience of performance of similar work executed
  - 5) The T&P for the work will be arranged by the agency

10. Work completion Period:- After receipt of work order for Oil filtration of 132/33 kV 25 MVA AREVA make T/F at 132 kV Substation Sengaoon, the work shall be completed within outage if required to be availed by MSETCL otherwise penalty @ 1% per week subject to max.10% of the order amount will be levied at the discretion of the Competent Authority.
11. Testing of oil:- The contractor should have calibrated oil testing facility with his filtration plant for testing of oil, its PPM, BDV etc. Testing of oil samples and IR values of power transformer should be recorded at following intervals in presence of MSETCL representative.

a) Before filtration b) During filtration at least three records c) After filtration


In case of non availability of any of the testing facility due to unavoidable reasons the contractor shall arrange for testing of oil by outside lab at his own cost. Testing during filtration will be part and partial process and no extra charges will be paid by MSETCL.

The transformer oil after filtration should confirm to IS specification.

12. The undersigned reserves the right to place order either partly or fully or to reject any or all the quotations without assigning any reasons whatsoever.
13. All the MSETCL's general terms & conditions for purchase will be binding on you.

Thanking you.

Yours faithfully,



**Executive Engineer**  
**EHV Projects Division Nanded.**

**Copy SWRT:-**

The Superintending Engineer, EHV Project Circle, Aurangabad.

**Copy to:-**

1. The Mgr (F&A), EHV Projects Division Nanded
2. Website:- [www.mahatransco.co.in](http://www.mahatransco.co.in)



**MAHARASHTRA STATE ELECTRICITY TRANSMISSION CO. LTD.**

**CIN No.U40109MH2005SGC153646**

<b>Name of Office</b>	<b>: - EHV PROJECT DIVISION, NANDED.</b>
<b>Office Address</b>	<b>: - 132 KV S/S JANGAMWADI, CAMPUS, MSETCL NANDED-431605</b>
<b>Contact No.</b>	<b>: - 02462 - 263105 (O), 02462 - 264107 (Fax), 02462 - 260107 (P)</b>
<b>Email</b>	<b>: - ee2630@mahatransco.in ;</b>

**Schedule- "A"**

**Schedule:-** Work of Oil filtration of 132/33 kV 25 MVA AREVA make T/F at 132 kV Substation Sengaon under EHV Projects Division Nanded.

<b>Sr. No.</b>	<b>Particulars of Work</b>	<b>Unit</b>	<b>Qty per Unit</b>	<b>Rate per Unit in Rs.</b>	<b>Amount</b>
1	Filtration / Degassing of Transformer oil in EHV Power Transformer by availing outage on Transformer	Per Ltr	19500	1.75	34125
	GST@18%				6142.5
	Labor Cess @1%				341.25
<b>Total</b>					<b>40608.75</b>


<b>Rate to be quote by agency in % only on per Litre in Figure</b>	<p>.....% Above</p> <p>.....% Below</p>
<b>Rate to be quote by agency in % only on per Litre in Words</b>	

**Tax:-** GST will be inclusive or specify clearly.

**Note:-**

The Desired values :-

- BDV as per IS:6792:1992
- PPM as per IS:13567:1992
- Acidity as per IS:1448(P-2):1967

  
**Executive Engineer**  
**EHV Projects Division Nanded.**