

Ref: SE/EHV/O&M/Circle/Pune/T/ Enquiry / 1961

Date :17.09.2019

E-ENQUIRY FOR BUDGETORY OFFER

TO WHOM SO EVER

Subject: Enquiry for Budgetary offer to Procurement neutral Ground Resistance (NGR) 220KV Bhosari I and 220KV Phursungi S/sn at EHV O&M MSETCL Circle office Pune

Sir,

It is to informed that , this office is looking for reasonable rate for procurement Neutral Ground Resistance (NGR) 220KV Bhosari I and 220KV Phursungi S/sn . Therefore , all interested agencies are requested to submit your reasonable budgetary offer for above work through e-mail se6100@mahatransco.in upto 23.09.2019 . The bidder can submit the offer to this office . The specification of NGR are described in schedule A .

Thanking you,

Yours faithfully,

Sd/-
(V. D. Bhujbal)
Superintending Engineer (I/C)
EHV(O&M) Circle, Pune 11.

SCHEDULE 'A'

Sr. No	Description	Unit	Qty	Rate /unit
1.	Neutral Ground Resistance (NGR) 1. Air Core , Dy Type 2. Epoxy Impregnated 3. Impedance - 1.0 Ohm 4. Rated continues current = 100 A 5. Rated short time current = 6000A/3sec 6. Winding material - Copper 7. Mounting : Vertical , Pedestal 8. Single Phase 33 KV , 50Hz 9. Insulation class : F 10. BIL : 70 KV / 170 KVp	Nos.	8	To be quoted

Sd/-
(V.D.Bhujbal)
Superintending Engineer(I/C)
EHV(O&M) Circle, Pune 11.