

MAHARASHTRA STATE ELECTRICITY TRANSMISSION COMPANY LTD.

Executive Engineer, MSETCL, EHV O&M Dn., Sangli
Office building, Vishrambag, Tal- Miraj Dist. Sangli- 416415

Contact No.:- 0233-2305816 (O)

0233- 2304872 (P)

0233-2304873 (F)

E-mail ID – ee3120@mahatransco.in

Website – www.mahatransco.in

CIN NO-U40109MH2005SGC153646

Ref No. EE/EHV O&M/DN/SGL/T/ No.

NO 10 15


Date : **15 AUG 2020**

**AMENDMENT in Rfx No. 7000016999 For Schedule “A” should be read
as**

It is to inform you that this office SRM-Tender Rfx No. 7000016999, for the Supply of 5KV High Voltage Insulation Testing Kit for 220KV Vita S/Stn and 220KV Miraj S/Stn under EHV O&M Division Sangli, **Schedule “A”** **HEREWITH AMENDED AS BELOW.**

Schedule “A” :- Supply of 5KV High Voltage Insulation testing Kit under EHV O&M Division, Sangli Test Parameter Specifications:- Test Regimes (Automatic) : IR, Leakage Current, PI, DAR, DD, SV & BDV Test Voltage : 250V to 5KV in 50V steps: Test Voltage Accuracy : $\pm 5\%$ Short Circuit Current : **5 mA**

**IT IS REQUESTED TO GO THROUGH AMENDMENT.
ALL REMAINING TERMS AND CONDITIONS REMAINS UN-CHANGED.**


EXECUTIVE ENGINEER
EHV O&M DIVISION SANGLI