

MAHARASHTRA STATE ELECTRICITY TRANSMISSION CO. LTD.

CIN No.U40109MH2005SGC153646

From: The Executive Engineer, EHV(O&M) Division, Kalwa Bramhaputra Building, 2 nd floor, Power House Complex, Post Box No 4, Airoli, Thane-Belapur Rd., Navi Mumbai- 400708. E-mail ID – ee7120@mahatransco.in/ ee7120@gmail.com , Website : www.mahatransco.in	To, As per mail list
--	--------------------------------

No.EE/EHV/O&M/KLW/Tech/ 840

dt. 17.08.2020

Sub.:- Enquiry towards submission of “Budgetary offer for the work of restoration of 220KV XLPE Cable termination of 220KV Kharghar-Borivali -2 line under EHV O&M Division Kalwa.

Dear Sirs/Madam,

In connection to above subject, the 220KV Kharghar-Borivali -2 line tripped on dt. 11.08.2020. The tripping occurred due to the B phase cable termination bushing, cable punctured at Loc. No. CTT-1. The 220KV Kharghar-Borivali -2 line kept under breakdown.

Considering above it is requested to submit your most reasonable & economical budgetary offer for the work of restoration of 220KV XLPE Cable termination of 220KV Kharghar- Borivali -2 line. The offer should clearly indicate FOR Destination price with all applicable taxes & duties in INR.

The broad Scope of work is as mentioned below;

Sr. No.	Particulars	Qty	Unit	Rate in Rs.	Amt. in Rs.
<u>Erection Part:-</u>					
	220KV XLPE Cable resotation work				
1	Tools and tackles required for jointing work	1	EA		
2	Megger testing of cable	1	EA		
3	De-clamping the cable, Isolating/cutting the faulty cable part near the existing termination	1	EA		
4	Excavation for pulling out cable loop from the loop made under ground, backfilling the excavated area with the excavated soil	1	EA		
5	Cable erection on tower with proper cleating arrangement	1	EA		
6	Supply and erection of scaffolding up to termination level	1	EA		
7	Provision of Skilled manpower and labour required for Jointing work	1	EA		

8	Provision of workmen's compensation of Jointing team	1	EA		
9	Dismantling of faulty termination including hydra charges	1	EA		
10	Formation of 220KV cable straight through joint	1	EA		
11	Formation of 220KV cable termination	1	EA		

It is to mention that, all required material such as 220KV Power cable, termination & link boxes will be provided by MSETCL. It is requested to submit the Budgetary Offers (valid for 6 months) to this office on or before 24th August, 2020 at 11:00 a.m. along with technical specification to this office on mail id: ee7120@mahatransco.in. The tentative period for completion of work may also be communicated.

Anyone other than the list of vendors who fulfills above conditions are also invited to submit their budgetary offer and technical specifications for the same.

Please treat this as MOST URGENT.

Thanking you in anticipation.

Yours faithfully,



**Executive Engineer
EHV O&M Dn. Kalwa**