

MAHARASHTRA STATE ELECTRICITY TRANSMISSION CO. LTD.
CIN No.U40109MH2005SGC153646.

Office of the Superintending Engineer(Civil) :
E.H.V.Civil Construction cum Maint.Circle, Pune
Block No.407, 3rd Floor, New Administrative Building,
Rasta Peth, PUNE 411 011,Phone :- 020-26120818(P);
E-Mail: se6700@mahatransco.in

SEC / PUNE / Civil / Tech/FL No.-

/Out No.

472

Dt. 22 JUN 2021

CORRIGENDUM-I

Sub. :- Permanent water supply to 400kV Lonikand S/stn Tal-Haveli, Dist-Pune from intake well at Bhima river near Bhima Koregaon,Dist-Pune.

Tender :- SEC/EHV /CCCM/Circle/Pune/ Tech/T-01/2021-22.

Following corrigendum is issued.

1.Item no 60 to be read as "Providing D.I.pipes push on joints pressure pipes of D.I.of K7 class and of 150 mm diameters confirming to the I.S.specification inclusive of cost of jointing material (Rubber gasket of EPDM Quality) including GST levied by GOI & GOM in all respect including third party inspection charges of TPI agency approved by MJP including transit insurance, Railway Freight , Unloading from railway wagon, Loading into Truck , Transporting to departmental store, unloading, and stacking etc.complete as directed by Engineer in charge. (IS 1536 / 2001 for pipes and IS 158/ 1969 and 12820 / 1989 or latest edition / revision with amendments for Rubber Gaskets)"

2.Due date of submission is 28/06/2021 upto 23.59 Hrs. instead of 24/06/2021

Upto 11.00Hrs.


3. Due date of opening : - a) Technical Bid on 29/06/2021 after 12.30 Hrs. instead of

25/06/2021 after 11.30 Hrs. (If possible)

b) Commercial Bid on 30/06/2021 after 12.30 Hrs. instead of

28/06/2021 after 11.30 Hrs. (If possible)

Other terms and conditions remain unchanged.


Superintending Engineer(C),
EHV C.C.C.M. Circle, Pune.