

MAHARASHTRA STATE ELECTRICITY TRANSMISSION CO. LTD.
(CIN : U40109MH2005SGC153646)

Office of the Executive Engineer

EHV (O&M) Dn. Boisar

At & Post Saravali Tal. Palghar Dist. Palghar Pin 401 501

Contact No.: (O) 9167640570

Email Id.: ee7130@mahatransco.in

Website: www.mahatransco.in

EE/EHV/O&M/DN./BSR/ T/P-7B/1419

Date: 28.09.2021

AMENDMENT FOR E-TENDER

Sub: Amendment of Technical Specification for strengthening of neutral earthing by providing additional earthing (double) to ICT/PTR at various S/S under EHV O&M Division Boisar.

Ref: This office E-Tender No. EE/EHV/O&M/DN./BSR/Tech/SRM-E-Tender-25/2021-22
(RFx No. 7000020967)

With reference to the above subject, this is to inform all concerned bidders that the SRM E-Tender for strengthening of neutral earthing by providing additional earthing (double) to ICT/PTR at various S/S under EHV O&M Division Boisar was published on dated 18.09.2021 mentioned under ref. 1. However Technical specification for 50x8 mm Copper Flat was wrongly mentioned as MS Flat in the tender document, thus please find below the detailed technical specification required for the above said E-Tender.

Specifications for WTI& OTI

Sr. No.	Material No.	Existing Technical Specification of Item No.	Revised material no.	Revised Technical Specification of Item No.
1	500008038	50x8 mm MS Flat for Trench	500007946	50x8 mm Copper Flat for Transformer LV neutral earthing

All other terms & condition are same & available on SRM E-Tender portal. Concerned please be noted.



(Rajesh Dakhane)

Executive Engineer,
EHV (O&M) Division Boisar