


MAHARASHTRA STATE ELECTRICITY TRANSMISSION CO.LTD

CIN No. U40109MH2005SGC153646

Name of Office	:	Office of the Executive Engineer	 MAHATRANSCO Maharashtra State Electricity Transmission Co. Ltd. स्वातंत्र्याचा अमृत महोत्सव
Office Address	:	400kV R.S.(O&M) Division, Babhaleshwar, A&P. Pimpri Nirmal, Tq. Rahata, Dist. Ahmednagar – 423107	
Contact No.	:	7768000276 / 7768001137	
Email Id	:	ee5130@mahatransco.in	
Website	:	http://www.mahatransco.in	

Ref.No. EE/400kV/RS/Dn/BBLR/Tech/473

Date:24.06.2022

Notification Inviting Budgetary Offer

Sub: Provide budgetary offer for providing and fixing of Turbo Wind Driven Bird Guard to various 400kV Lines under the jurisdiction of 400kV Line Maintenance S/Dn Babhaleshwar under 400KV RS (O&M) Division, Babhaleshwar.

In connection with the above subject, it is requested to furnish the budgetary offer for providing and fixing of Turbo Wind Driven Bird Guard to various 400kV Lines under the jurisdiction of 400kV Line Maintenance S/Dn Babhaleshwar under 400KV RS (O&M) Division, Babhaleshwar. The specifications of Turbo Wind Driven Bird guard are mentioned below:

Sr No.	Particulars of work	Unit	Qty.	Rate
1	Providing “Turbo Wind Driven Bird Guard” For 400kV Line Towers Specifications:- 1) Size:- Should be maintained Standard Electrical Clearances on 400kV Line Phases Neck Diameter:-300 MM Overall Height:- 350 MM Spinning Diameter:- 375 MM 2) Material Grade for fins &Frame: Aluminium 8055 3)Nominal Thickness of Fins:0.50 TCT MM 4)Mounting arrangement H.D.G. Mild steel 5) Bearing are covered with plastic caps 6) Nominal wind Pressure: 80kM/Hr 7)RPM Capacity :500 RPM 8) Yield strength :240 MPA 9) Glow bands Marking on the borders of the Fins for safety and Visibility in Night. Corrosion Resistant, Light weight, Flexible Design, Rust proof, Excellent Finished.	Nos.	At Actual	
2	Fixing of “Turbo Wind Driven Bird Guard” for 400kV Lines S/C / D/C, Horizontal / Vertical Towers.	Nos.	At Actual	

The Guarantee / warranty period for Turbo Wind Driven Bird Guard is 12 months from installation.

Vendors are requested to submit their budgetary offer for above said work on or before 06.07.2022 on the email id: ee5130@mahatransco.in

Sd/-
Executive Engineer
400kV R.S.(O&M) Division
Babhaleshwar