

MAHARASHTRA STATE ELECTRICITY TRANSMISSION CO. LTD. EHV (O&M) DIVISION, AKOLA

Office of
Executive Engineer
EHV (O&M) Division, Akola

2nd Floor, Vidyut Bhawan, Ratanlal Plots, Akola - 444 005

Tele: 0724-2410356 Email Id.: ee1210@mahatransco.in

Website: www.mahatransco.in

No.: EE/EHV/O&M/DN/AKL/Tech//484

Date: 03-10-2022

E - ENQUIRY

Subject: Enquiry for work of providing & fixing of Multifunction Digital Energy Meter at various Substation under EHV O&M Division, Akola.

Ref

- :1. Enquiry No. EE/EHV/O&M/DN/AKL/Tech/ 1393 Dt. 09.09.2022
- 2. Enquiry No. EE/EHV/O&M/DN/AKL/Tech/ 1454 Dt. 21.09.2022

Dear Sir,

Sealed and superscripted quotations are invited for work of providing & fixing of Multifunction Digital Energy Meter at various Substation under EHV O&M Division, Akola. The quotation giving full particulars should reach this office on or before Dt. 10.10.2022 at 13.00 Hrs positively subject to the following terms and conditions and Schedule A (attached separately). Quotations will be opened on the same day at 15:00 Hrs, if possible.

SCHEDULE - A

| Sr | Description of Unit | Unit | Qty. | Ex. Rate (Including labour Cess & Excluding GST) |
|----|--|------|------|--|
| 1 | Providing & fixing of Multifunction Digital Energy Meter (SAP No. 50011086) (as per technical specifications attached) | EA | I | |

GST @18% will be paid extra.

Terms & Conditions

- 1) The quotation must be forwarded in sealed envelope duly super scribed with all details i.e. I. Enquiry No. & Date: III. Quotation for:-
- 2) The quotation must be written with ink or typewritten. Any as catching or over writing must be initialed.
- 3) Rates: Rates should be quoted inclusive of all taxes except GST. GST will be paid extra.
- 4) Period of Work Completion: The work shall be completed within 45 days from the date of handing over of site by the authority concerned S/Stn In-charge / Addl. Executive Engineer. The decision of the concerned S/Stn In-charge will be final in this regard.

- 5) Security deposit: Security deposit @ 5% of the order value will have to be deposited to this office within 07 days after confirmation of work order.
- 6) Agreement Bond: Agreement to be executed on stamp paper of Rs. 500/-at your cost & should be submitted to this office within 7 days from the receipt of this work order.
- 7) Penalty: If the agency fails to execute the work within stipulated period mentioned above then, the penalty @ of ½ % per week maximum 10 % shall be levied on contact value.
- 8) T & P/ Labour: No T & P and labour will be provided by the MSETCL.
- 9) REQUIRED DOCUMENTS:
 - 1) GST Registration and PAN copy.
 - 2) Shop Act License.
 - 3) Experience certificate / work completion certificate for execution of similar type of works.
 - 4) Electrical Contractor license.
- 10) The agency must have experience of carrying out the similar type of work.
- 11) Workmanship: Your workmanship shall be best & shall be guaranteed for one year. During this period, if any defects are developed / observed, the same will have to be attended by quote at his cost only.
- 12) Statutory Obligation: The Company will not be responsible for any mishaps/accidents to agencies workmen etc. during & after execution of work. All applicable statutory rules, laws will have to be observed by agency, MSETCL will not be responsible for any consequences.
- 13) Taxes: GST and other applicable taxes will be deducted as per rules while effecting the payment.
- 14) Loss / Damages: For damages if caused to companies property during execution of work the compensation depending upon nature of damage &/or as estimated by Engineer Incharge will be recovered from quote.
- **15) Exception:** No outages will be extended for execution of the said work however in any exceptional case; same will be extended after observing all other formalities and considering the system condition.
- 16) Payment: 100 % payment will be done at the earliest depending upon availability of funds.
- 17) Discretion: The undersigned reserves the right to reject any or all quotation without assigning any reasons thereof.

Thanking you,

Executive Engineer EHV (O&M) Division, Akola Technical Specifications for Microprocessor Based Multifunction Energy Meters:

| | eations for Microprocessor Based Mu Parameters | Description |
|------------------|---|--|
| | PT Secondary | Onsite programmable 100600V L-L |
| | | (57.7 346V L-N) |
| | PT Primary | 100V692kV LL |
| | | (Programmable on site) |
| | Measuring voltage range | 20% 120% of rated value |
| | Voltage Overload Withstand | 2 X rated value for 1sec, repeated 10 times at 10 second intervals |
| | Voltage Input VA Burden | < 0.35 VA approx. per phase |
| | CT Secondary (Onsite Programmable) | 1A/5A RMS |
| VAF | CT Primary (Onsite Programmable) | 19999A |
| | Measuring current range | 5mA6A |
| | Max continuous input current | 120% of nominal value |
| | Current Overload Withstand | 20x rated value for 1sec, repeated 5 |
| | | times at 5 min |
| | Current Input VA Burden | < 0.3 VA approx. per phase |
| | Frequency | 4070 Hz |
| | Sampling frequency (50 Hz) | 1.6 kHz / phase |
| | Overvoltage category | CAT III |
| | Maximum Power measured per phase | 462.962 MVA Per phase |
| | Energy Roll over Count | 14 digit (W -7 to 14; kw - 7 to 12; MW - 7 to 9) |
| Communication | RS485 MODBUS Communication | RS485 Port with Modbus communication and 20x User Assignable registers |
| | Power Supply Range | 60 – 300 VAC /DC or 12 – 60VAC/DC |
| Auxiliary Supply | VA Burden | < 6.5 VA approx. |
| | Frequency | 4566Hz |
| | Voltage | 0.2% |
| | Current | 0.2% |
| | Frequency | 0.15% |
| | Power (Active) | 0.2% |
| A a | Power (Re-active) | 0.4% |
| Accuracy | Power (Apparent) | 0.2% |
| | Energy (Active) | 0.2% |
| | Energy (Re-active) | 0.2% |
| | Energy (Apparent) | 0.2% |
| | Temperature range | -10 +55 °C |
| Environment-1 | Relative humidity | 0 90%RH (non condensing) |
| Environmental | Degree of pollution | 2 |
| | Display Type | Color TFT (Touch screen) |
| | Parameter Digit Resolution | 4 |
| Display | No. of simultaneous display | 3 |
| Market | parameters | |
| Mechanical | Weight (g) | 500 |

| Properties | Device dimensions in mm (H x W x D) | 96 x 96 x 80 |
|------------|--|---|
| | Protection class | Front: IP54 (Option to fix IP65 Kit without changing the meter), Rear: IP20 |
| | Mounting of Instrument | Panel Mounting |
| | Connecting phase (U / I), Single core, multi-core, fine- stranded Terminal pins, core end sheath | 2.5 mm ² x 2 fine wire or 4 mm ² single wire |

$\label{thm:correction} \textbf{The Microprocessor Based MFM Meter Should Display Following Parameters:}$

| Parameters | |
|--|----------|
| Voltage | V |
| Current | V |
| Frequency | V |
| Power (Active) | V |
| Power (Re-active) | V |
| Power (Apparent) | 1 |
| PF (Power Factor) | V |
| Energy (Active) | V |
| Energy (Re-active) | V |
| Energy (Apparent) | V |
| User Selectable 3PH 3W/4W | V |
| On site CT Primary Programmable | V |
| On Site CT Secondary Programmable (1 / 5A) | V |
| On Site PT Primary Programmable | V |
| On Site PT Secondary Programmable | 1 |
| Onsite selection of Auto scroll / Fixed Screen | V |
| Password Protection | V |
| Min / Max Storage Value (System Voltage / Current) | V |
| Phase Angle | 1 |
| True RMS measurement | V |
| THD Measurement | 1 |
| Parameter Screen recall | √ |
| Run Hour | 1 |
| ON Hour | 1 |
| Number of Interruptions | √ |
| Phase Reversal Indication | √ |
| Neutral Current | |
| Current Reversal Indication | V |
| Phase Absent Indication | V |
| Demand Current | V |
| Demand Active Power | |
| Demand Apparent Power | |
| Max. Demand Current | V |
| Max. Demand Active Power | V |
| Max. Demand Apparent Power | V |
| Limit (Alarm) / Pulse Relay output (Optional) | V |
| Parameters | |

| Programmable Energy format & Energy rollover count | |
|---|--|
| User selectable Low Current Suppression √ | |
| Phaser Diagram (Pictorial Representation) √ | |
| VA waveform (Pictorial Representation) √ | |
| Communication MODBUS RS 485 (Plug and play card Facility) √ | |

The Microprocessor Based MFM Meter Should meet following Standards:

| EMC | IEC 61326 |
|-----------------------|--|
| Immunity | IEC 61000-4-3. 10V/m min – Level 3 industrial Low level |
| Safety | IEC 61010-1-2001, Permanently connected use |
| IP for water & Dust | IEC60529 |
| Installation Category | III |
| High Voltage Test | 2.2 kV AC, 50Hz for 1 minute between all electrical circuits |
| Test and Procedure | IS 13875 |
| Pollution degree | 2 |

Executive Engineer EHV O&M Division, Akola