

## “Corrigendum for RFx No. 7000026147”

TQR Sr. No.	Existing specifications	Revised specifications
12	Bidder should attach the Test Certificate satisfying technical specification as mentioned on Page No. 15. Sr. No. B) Insulation mat would be tested by CPRI for IS:15652:2006 having 2” wide safety glow bands and both side mentioned in the test report.	Bidder should attach the Test Certificate satisfying technical specification as mentioned on Page No. 15. Sr. No. B) Insulation mat would be tested by <b>CPRI /ERDA</b> for IS:15652:2006 having 2” wide safety glow bands and both side mentioned in the test report.

All other terms & condition of the RFx No. 7000026147 will remain the same. All eligible bidders please make note of the above changes.



**Executive Engineer,  
EHV (O&M) Division,  
MSETCL, Bhandara**