



MAHARASHTRA STATE ELECTRICITY TRANSMISSION CO. LTD.
(CIN No.U40109MH2005SGC153646)

Name of Office:Central Purchase Agency,
Office Address:Prakashgad, 1st Floor, Plot No. G-9, Anant Kanekar Marg, Bandra (East),
Mumbai-51
Contact No.: 022-26474211/26472131
Email Id: cecpa@mahatransco.in
Website: www.mahatransco.in

SP/T-0701/0621/

Date: 08.07.2021

AMENDMENT NO.-I

Sub: Procurement of 400 KV Hanging and Pedestal Type Wavetraps for various EHV PCC
O&M Zones of MSETCL against e-Tender No. SP/T-0701/0621 [RFx. No. 5*927] -
**Issue of Clarification/ Amendment to tender document in response to Bidder's
queries and extension in due date of submission and opening of bid.**

Please refer e-Tender No. SP/T-0701/0621 [RFx. No. 5000000927], advertised for
procurement of 400kV Hanging and Pedestal Type Wave traps.

In response to above tender, the **Clarifications / Amendments to Tender specifications on
bidder's queries** are given in Annexure-I enclosed herewith.

Considering the above, the due dates of submission and opening of Tender are hereby
modified as under:

Due date and time of submission of bids : 23.07.21 up to 17.00 Hrs.

Due date and time of opening of bids : 23.07.21 at 17.15 Hrs.

All participant bidders are requested to take note of the above and submit their bids
accordingly. All other terms and conditions of the Tender specifications remain unchanged.

- sd -
Executive Engineer (St.-VII)

Annexure - I (Clarification to Pre-Bid Queries)

SP/T-0701/0621 [Procurement of 400 kV Hanging and Pedestal Type Wavetraps] - RFX : 5000000927

Sr. No.	Clause reference	Specification requirements	Bidder's Query	Clarification	Amendment to Tender
1	2	3	4	5	6
1	Clause 4.0 of Special Terms and conditions.	The desired delivery is commencement within Two months from the date of L.O.A (Letter of Award) and completion within Four Months	We request for the delivery commencement period of 4 Months from the date of LOA as we need to secure the credential approval before proceeding further for order execution and completion thereafter two months.	The commencement period as indicated at Cl. No. 2.0 (a) of Section III (Special Terms and Conditions) is hereby amended as indicated in column no. 6.	The desired delivery is commencement & completion within Four months from the date of L.O.A (Letter of Award)
2	Clause 1.2 (I) of Technical Speification.	Supply of Line Trap along with all the required accessories.	The List of Suspension Accessories require is not defined in the specification i.e. Disc insulator, Mounting plate etc. Please confirm the requirement of Suspension accessories in detail.	<p>The following accessories are to be supplied with the Line Traps (Suspension and Pedestal) as indicated in Cl. No. 4.10 of Technical Specification: (i) Bird Barrier (ii) Terminals.</p> <p>The Suspension Type Line Traps are to be supplied without insulators but with all standard mounting accessories. Further, in case of Pedestal Type Line Trap, Solid Core Post Insulators, Lattice Type Equipment support structure & mounting plate are to be provided alongwith the equipment.</p>	--- NIL ---
3	Clause 8.0 of Section-II	Security Deposit	Bank Guarantee format for Security Bank Guarantee are not enclosed along with Tender. Kindly share SD BG format.	The Security Deposit and Performance Bank Guarantees are to submitted after placement of order and hence will be issued after placement of order.	--- NIL ---
4	Clause 9.0 of Section-II	Performance Security Deposit	Bank Guarantee format for Performance Bank Guarantee are not enclosed along with Tender documents. Kindly share PBG format.		
5			Request you to clarify if the lattice structure & post insulators are also to be quoted along with the wave trap price	<p>The scope of work is already defined in Cl. No. 1.2 of Technical Specification of Tender Document. The same is mentioned herewith for ready reference.</p> <p>The Pedestal Type Wavetraps are to be supplied alongwith Solid Core Post Insulators and Lattice Type Equipment Structure. Accordingly, the per unit price to be quoted for the item shall include the cost for Solid Core Post Insulators and Lattice Type Equipment Structure (own make or bought out item) conforming to MSETCL's design & specification.</p>	--- NIL ---

Annexure - I (Clarification to Pre-Bid Queries)

SP/T-0701/0621 [Procurement of 400 kV Hanging and Pedestal Type Wavetraps] - RFx : 5000000927

Sr. No.	Clause reference	Specification requirements	Bidder's Query	Clarification	Amendment to Tender
6			Requirement of Annexure-B1	With regards to 'Annexure-B1' of Technical Specification, as mentioned in notes thereunder: (i) The Unit Rate (per MT) for Steel, Nuts & Bolts to be quoted therein are for computation of price in case of any increase or decrease in guaranteed weight of wavetrap support structure as mentioned in clause no. 1.5 & 1.7 of Annexure - C of technical specification. (ii) The Unit rate (per No.) of post insulator to be quoted therein are for computation of price in case of any increase or decrease in quantity. (iii) The above unit rates shall not be considered for bid evaluation.	--- NIL ---
7			Line Trap: We can supply LT along with bird barrier / Corona rings / three point suspension arm & not suspension string/clamps /hardware: Kindly confirm	Refer clarification at Sr. No. (2) above.	--- NIL ---
8			Lattice Structure: Is there any approved source as per MSETCL or can MSETCL provide clear drawings of metallic structure. Is it possible to share the supplier details.	As already mentioned at Clause No. 1.2 of TECHNICAL SPECIFICATION FOR EQUIPMENT SUPPORT STRUCTURE (Annexure C), the structures shall be of approved makes as listed on MSETCL website i.e. https://www.mahatransco.in (Supplier services -> MSETCL's Approved Vendor List). The structural drawing for 400 kV Pedestal Type Wavetrap attached with the specification at pg. no. 28 is clear and legible.	--- NIL ---
9			Post Insulator: Is there any approved source as per MSETCL, if yes, can the supplier details be arranged from whom we can directly purchase the BPI	As already mentioned at Clause No. 1.5 of TECHNICAL SPECIFICATION FOR POST INSULATORS (Annexure B), the buspost insulators shall be of approved makes as listed on MSETCL website i.e. https://www.mahatransco.in (Supplier services -> MSETCL's Approved Vendor List).	--- NIL ---