



Amendment No. 1

Tender No.: T-2202/MSETCL/CO/Tr. O&M/SE-I/EE-II/HYB (RFx No. 7000024069).

Name: Supply, Installation, Testing and Commissioning of 245kV Hybrid Switchgear as bus sectionalizer at 220kV Temghar, 220kV Kamba, 220kV Nalasopara and 220kV Wada substations under Kalwa Circle.

The Maharashtra State Electricity Transmission Company Ltd., Mumbai, has invited offers in TWO bid system (Techno- commercial and price bid) from the eligible bidders for the work of Supply, Installation, Testing and Commissioning of 245kV Hybrid Switchgear as bus sectionalizer at 220kV Temghar, 220kV Kamba, 220kV Nalasopara and 220kV Wada substations under Kalwa Circle vide SRM e-Tender No. T-2202 (RFx No. 7000024069).

Bidders are requested to note following:

- Reply to pre-bid queries are uploaded along with respective documents.
- The Tender Document Part-V General Technical requirements of Hybrid Switchgear as a Bus Sectionalizer, Clause no. 5.2.6 for Combined Isolator (Disconnecter)/Earthing Switch should be read as:

The Disconnecter and **grounding** switch motor should be AC/DC operated as per the substation AC/DC Voltage.

All other contents remains unchanged. The bidders are requested to check the details on our website www.srmetender.mahatransco.in.


Executive Director (Operations)