



**MAHARASHTRA STATE ELECTRICITY TRANSMISSION CO. LTD.**  
**(CIN No.U40109MH2005SGC153646)**

**Name of Office:** Central Purchase Agency,  
**Office Address:** Prakashgad, 1<sup>st</sup> Floor, Plot No. G-9, Anant Kanekar Marg Bandra (East),  
Mumbai-51  
**Contact No.:** 022-26474211/26472131  
**Email Id:** cecpa@mahatransco.in  
**Website:** www.mahatransco.in

SP/T-0801/0123

Date: 10.03.2023

**AMENDMENT NO. - III**

**Sub:** Procurement of 400 KV, 220 KV & 132 KV porcelain long rod insulators for various zones of MSETCL against e-Tender No. SP/T-0801/0123 [RFx. No. 5000001101] – **Clarification to bidder's queries and Extension in due date of submission and opening of bid thereof.**

\*\*\*\*

Dear Sirs,

Please refer e-Tender No. SP/T-0801/0123 [RFx. No. 5000001101], advertised for procurement of 400 KV, 220 KV & 132 KV porcelain long rod insulators for various zones of MSETCL.

In response to above tender, the **Clarifications / Amendments to Tender specifications on** bidder's queries is as under:

<b>Bidder's Query</b>	<b>Purchaser's Clarification/ Response</b>
As per technical specifications of Insulators for 70KN/120KN/160KN DISC/ LONGROD INSULATORS Sl. No. 6.1.1 (e) voltage distribution test on 400KV String of 120KN & 160KN insulators, please note that this test is applicable on disc insulators only. On Long Rod Insulators, this test is not applicable.  MSETCL has also confirmed the same at Sl. No. 6.1.B (d) for 220KV String of 70KN & 120KN insulators i.e. voltage distribution test is applicable on Disc Insulators only.  Please clarify and confirm.	As applicable in case of 220kV string Voltage distribution test shall be applicable for Disc Insulator string to be used for 400kV system. For 400kV Longrod Insulator, the said test is not applicable.

Further, the due dates of submission and opening of Tender are hereby modified as under:

**Due date and time of submission of bid** : 14.03.2023 up to 17.00 Hrs  
**Due date and time of opening of bid** : 14.03.2023 at 17.15 Hrs

All participant bidders are requested to take note of the above and submit their bids accordingly. All other terms and conditions of the Tender specifications remain unchanged.

Yours faithfully,  
-sd-  
Executive Engineer (St. VIII)