

**MAHARASHTRA STATE ELECTRICITY TRANSMISSION CO. LTD.**  
**(CIN No.U40109MH2005SGC153646)**

**Name of Office:** Central Purchase Agency,  
**Office Address:** Prakashgad, 1<sup>st</sup> Floor, Plot No. G-9, Anant Kanekar Marg Bandra (East),  
Mumbai-51  
**Contact No.:** 022-26474211/26472131  
**Email Id:** cecpa@mahatransco.in  
**Website:** www.mahatransco.in

SP/T-0805/0323

Date: 27.04.2023

**AMENDMENT NO. - I**

**Sub:** Procurement of 400 KV, 220 KV & 132 KV (N) & (AF) Type porcelain long rod insulators for various zones of MSETCL against e-Tender No. SP/T-0805/0323 [RFx. No. 5000001097] – **Amendment to Technical Specification and Extension in due date of submission and opening of bid thereof.**

\*\*\*\*\*

Dear Sirs,

Please refer e-Tender No. SP/T-0805/0323 [RFx. No. 5000001097], advertised for procurement of 400 KV, 220 KV & 132 KV (N) & (AF) Type porcelain long rod insulators for various zones of MSETCL.

In response to above tender, the **Clarifications / Amendments to Tender specifications** on bidder's queries is as under:

<b>Bidder's Query</b>	<b>Original Clause</b>	<b>Amended Clause</b>
As per MSETCL Technical Specifications Clause No. 6.3 [II-C of e] <b>Voltage Distribution Test</b> on 400KV String of 120 KN & 160 KN Insulators, Please note that this Test is applicable on Disc Insulators only. On Long Rod Insulators, this Test is not applicable. MSETCL has also confirmed the same at Clause No. 6.3 [II-B of d] for 220KV String of 70 KN & 120 KN Insulators i.e. Voltage Distribution Test is applicable on Disc Insulators only.	<b><u>CLAUSE NO. 6.3 LIST OF TYPE TEST:</u></b>  <b>[II] On Complete insulator string with hardware fittings:</b>  <b><u>(C) On 400 kV String of 120 KN &amp; 160 KN insulators:</u></b>  e): Voltage distribution test	<b><u>CLAUSE NO. 6.3 LIST OF TYPE TEST:</u></b>  <b>[II] On Complete insulator string with hardware fittings:</b>  <b><u>(C) On 400 kV String of 120 KN &amp; 160 KN insulators:</u></b>  e):Voltage distribution test <b>(For Disc Insulators Only)</b>

Further, the due dates of submission and opening of Tender are hereby modified as under:

**Due date and time of submission of bid** : 08.05.2023 up to 17.00 Hrs  
**Due date and time of opening of bid** : 08.05.2023 at 17.15 Hrs

All participant bidders are requested to take note of the above and submit their bids accordingly. All other terms and conditions of the Tender specifications remain unchanged.

-sd-  
Executive Engineer (St. VIII)